

Licence 11149  
 Link to Licence <http://www.environment.nsw.gov.au/prpoeoapp/>  
 Name OneSteel Wire Pty Ltd  
 Address Industrial Drive, Mayfield, NSW, 2304  
 Location of Monitoring Point/Area Point 1

Monthly Summary for:

Mar-15

Sample Received

Monthly sample received 04/3/15 Other daily and continuous measurements performed through March 2015

Data Obtained

08-Apr-15

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured			Exceedance (Y/N)	Comments
			during month	Min value	Max value		
Nitrogen (ammonia)	mg/L	Monthly	1	N./A	4.3	30	N
Total Copper	micrograms/L	Monthly	1	N./A	<10	N/A	N
Total Iron	mg/L	Monthly	1	N./A	0.3	2	N
Total Lead	micrograms/L	Monthly	1	N./A	<10	50	N
Total Manganese	mg/L	Monthly	1	N./A	<0.1	0.5	N
Total Suspended Solids	mg/L	Monthly	1	N./A	1	20	N
Total Zinc	mg/L	Monthly	1	N./A	<0.1	2	N
pH	pH	Continuous	Continuous	7.7	8.16	6.5-8.5	N
Temperature	degrees Celsius	Continuous	Continuous	N/A	39.7	42	N
Volume	kL/day	Daily	Daily	96	519	700	N

Licence 11149  
 Link to Licence <http://www.environment.nsw.gov.au/prpoeoapp/>  
 Name OneSteel Wire Pty Ltd  
 Address Industrial Drive, Mayfield, NSW, 2304

Location of Monitoring Point/Area Point 39

Monthly Summary for: Mar-15  
 Sample Received Monthly sample received 3-3-15. oil and grease 5-3-15.  
 Other daily and continuous measurements performed through March 2015.

Data Obtained 10-Apr-15

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured		100 percentile limit	Exceedance (Y/N)	Comments
			during month	Min value Max value			
Chromium (hexavalent)	mg/L	Monthly	1	N/A <0.005	0.01	N	
Nitrogen (ammonia)	mg/L	Monthly	1	N/A <1	N/A	N	
Phosphate	mg/L	Monthly	1	N/A 0.7	10	N	
Total Copper	micrograms/L	Monthly	1	N/A <10	N/A	N	
Total Iron	mg/L	Monthly	1	N/A 0.3	5	N	
Total Lead	micrograms/L	Monthly	1	N/A <10	N/A	N	
Total Manganese	mg/L	Monthly	1	N/A <0.1	0.5	N	
Total Suspended Solids	mg/L	Monthly	1	N/A 2	50	N	
Total Zinc	mg/L	Monthly	1	N/A 0.2	3	N	
Oil and Grease	mg/L	Monthly	1	N/A <5	20	N	
pH	pH	Continuous	Continuous	7 7.86	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	N/A 37.6	38	N	
Volume	kL/day	Daily	Daily	0 349	200	N	

There were no rain discharges for the month of March.  
 There was one discharge for maintenance on the weekend of the 8th. of 349m3.