

Licence 11149
 Link to Licence <http://www.environment.nsw.gov.au/prpoeoapp/>
 Name OneSteel Wire Pty Ltd
 Address Industrial Drive, Mayfield, NSW, 2304
 Location of Monitoring Point/Area Point 1

Monthly Summary for: Dec-14
 Sample Received Monthly sample received 9/12/14 Other daily and continuous measurements performed through December 2014.
 Data Obtained 14-Jan-15

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured during month	Min value	Max value	100 percentile limit	Exceedance (Y/N)	Comments
Nitrogen (ammonia)	mg/L	Monthly	1	N./A	2	30	N	
Total Copper	micrograms/L	Monthly	1	N./A	24	N/A	N	
Total Iron	mg/L	Monthly	1	N./A	0.4	2	N	
Total Lead	micrograms/L	Monthly	1	N./A	15	50	N	
Total Manganese	mg/L	Monthly	1	N./A	<0.1	0.5	N	
Total Suspended Solids	mg/L	Monthly	1	N./A	6	20	N	
Total Zinc	mg/L	Monthly	1	N./A	<0.1	2	N	
pH	pH	Continuous	Continuous	7.7	8.26	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	N/A	41.5	42	N	
Volume	kL/day	Daily	Daily	0	413	700	N	

Licence 11149
 Link to Licence <http://www.environment.nsw.gov.au/prpoeoapp/>
 Name OneSteel Wire Pty Ltd
 Address Industrial Drive, Mayfield, NSW, 2304

Location of Monitoring Point/Area Point 39

Monthly Summary for: Dec-14
 Sample Received Monthly sample received 02-12-14. including Oil and Grease.
 Other daily and continuous measurements performed through December 2014.

Data Obtained 12-Jan-15

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured during month	Min value	Max value	100 percentile limit	Exceedance (Y/N)	Comments
Chromium (hexavalent)	mg/L	Monthly	1	N/A	<0.005	0.01	N	
Nitrogen (ammonia)	mg/L	Monthly	1	N/A	<1	N/A	N	
Phosphate	mg/L	Monthly	1	N/A	1.3	10	N	
Total Copper	micrograms/L	Monthly	1	N/A	<5	N/A	N	
Total Iron	mg/L	Monthly	1	N/A	0.1	5	N	
Total Lead	micrograms/L	Monthly	1	N/A	<5	N/A	N	
Total Manganese	mg/L	Monthly	1	N/A	<0.1	0.5	N	
Total Suspended Solids	mg/L	Monthly	1	N/A	1	50	N	
Total Zinc	mg/L	Monthly	1	N/A	0.2	3	N	
Oil and Grease	mg/L	Monthly	1	N/A	5.3	20	N	
pH	pH	Continuous	Continuous	7.1	7.9	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	N/A	37	38	N	
Volume	kL/day	Daily	Daily	0	1054	200	N	

One discharge under Licence condition L3.1 on the 20th December during shutdown maintenance.