

Licence 11149
 Link to Licence <http://www.environment.nsw.gov.au/prpoeoapp/>
 Name OneSteel Wire Pty Ltd
 Address Industrial Drive, Mayfield, NSW, 2304
 Location of Monitoring Point/Area Point 1

Monthly Summary for: Apr-14
 Sample Received Monthly sample received 17/04/14 Other daily and continuous measurements performed through April 2014.
 Data Obtained 02-May-14

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured				Exceedance (Y/N)	Comments
			during month	Min value	Max value	100 percentile limit		
Nitrogen (ammonia)	mg/L	Monthly	1	N./A	1	30	N	
Total Copper	micrograms/L	Monthly	1	N./A	<10	N/A	N	
Total Iron	mg/L	Monthly	1	N./A	0.4	2	N	
Total Lead	micrograms/L	Monthly	1	N./A	<10	50	N	
Total Manganese	mg/L	Monthly	1	N./A	<0.1	0.5	N	
Total Suspended Solids	mg/L	Monthly	1	N./A	2	20	N	
Total Zinc	mg/L	Monthly	1	N./A	<0.1	2	N	
pH	pH	Continuous	Continuous	7.7	8.2	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	N/A	39.6	42	N	
Volume	kL/day	Daily	Daily	0	537	700	N	

Notes: Plant not operational over Easter for 4 days.

Licence 11149
 Link to Licence <http://www.environment.nsw.gov.au/prpoeoapp/>
 Name OneSteel Wire Pty Ltd
 Address Industrial Drive, Mayfield, NSW, 2304
 Location of Monitoring Point/Area Point 39

Monthly Summary for: Apr-14
 Sample Received Monthly sample received 3-4-14. Oil and Grease sample received 2-4-14.
 Other daily and continuous measurements performed through April 2014.

Data Obtained 06-May-14

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured		100 percentile limit	Exceedance (Y/N)	Comments
			during month	Min value Max value			
Chromium (hexavalent)	mg/L	Monthly	1	N/A <0.005	0.01	N	
Nitrogen (ammonia)	mg/L	Monthly	1	N/A <1	N/A	N	
Phosphate	mg/L	Monthly	1	N/A 2.1	10	N	
Total Copper	micrograms/L	Monthly	1	N/A <5	N/A	N	
Total Iron	mg/L	Monthly	1	N/A 0.1	5	N	
Total Lead	micrograms/L	Monthly	1	N/A <5	N/A	N	
Total Manganese	mg/L	Monthly	1	N/A <0.1	0.5	N	
Total Suspended Solids	mg/L	Monthly	1	N/A 2	50	N	
Total Zinc	mg/L	Monthly	1	N/A 0.2	3	N	
Oil and Grease	mg/L	Monthly	1	N/A 5	20	N	
pH	pH	Continuous	Continuous	7.1 8.2	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	N/A 36.3	38	N	

Volume kL/day Daily Daily 0 295 200 N

Maintenance shutdown discharge utilised to exceed 200kL/day. See provision in Licence condition L3.1 (Note).