

Licence 11149
 Link to Licence <http://www.environment.nsw.gov.au/prpoeoapp/>
 Name OneSteel Wire Pty Ltd
 Address Industrial Drive, Mayfield, NSW, 2304
 Location of Monitoring Point/Area Point 1

Monthly Summary for:

Feb-13

Sample Received

Monthly sample received 14/02/13 Other daily and continuous measurements performed through February 2013.

Data Obtained

05-Feb-13

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured				Exceedance (Y/N)	Comments
			during month	Min value	Max value	100 percentile limit		
Nitrogen (ammonia)	mg/L	Monthly	1	N./A	<1	30	N	
Total Copper	mg/L	Monthly	1	N./A	<0.1	N/A	N	
Total Iron	mg/L	Monthly	1	N./A	0.2	2	N	
Total Lead	mg/L	Monthly	1	N./A	<0.01	0.05	N	
Total Manganese	mg/L	Monthly	1	N./A	<0.1	0.5	N	
Total Suspended Solids	mg/L	Monthly	1	N./A	<1	20	N	
Total Zinc	mg/L	Monthly	1	N./A	<0.1	2	N	
pH	pH	Continuous	Continuous	7.49	8.49	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	N/A	39.7	42	N	
Volume	kL/day	Daily	Daily	124	448	700	N	

Licence 11149
 Link to Licence <http://www.environment.nsw.gov.au/prpoeoapp/>
 Name OneSteel Wire Pty Ltd
 Address Industrial Drive, Mayfield, NSW, 2304

Location of Monitoring Point/Area Point 39

Monthly Summary for: Feb-13
 Sample Received Monthly sample received 4-2-13. Oil and Grease sample received 8-2-13.
 Other daily and continuous measurements performed through February 2013.

Data Obtained 11-Mar-13

Pollutant	Units of Measure	Monitoring frequency required by	No of times measured			100 percentile limit	Exceedance (Y/N)	Comments
		Licence	during month	Min value	Max value			
Chromium (hexavalent)	mg/L	Monthly	1	N/A	<0.005	0.01	N	
Nitrogen (ammonia)	mg/L	Monthly	1	N/A	<1	N/A	N	
Phosphate	mg/L	Monthly	1	N/A	0.63	10	N	
Total Copper	mg/L	Monthly	1	N/A	<0.1	N/A	N	
Total Iron	mg/L	Monthly	1	N/A	0.8	5	N	
Total Lead	mg/L	Monthly	1	N/A	<0.005	N/A	N	
Total Manganese	mg/L	Monthly	1	N/A	<0.1	0.5	N	
Total Suspended Solids	mg/L	Monthly	1	N/A	7	50	N	
Total Zinc	mg/L	Monthly	1	N/A	0.8	3	N	
Oil and Grease	mg/L	Monthly	1	N/A	2	20	N	
pH	pH	Continuous	Continuous	7.9	8.4	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	N/A	36.6	38	N	
Volume	kL/day	Daily	Daily	0	285.8	200	N	Licence condition L4.3 utilised to exceed 200kL/day.