

Licence 11149  
 Link to Licence <http://www.environment.nsw.gov.au/prpoeoapp/>  
 Name OneSteel Wire Pty Ltd  
 Address Industrial Drive, Mayfield, NSW, 2304  
 Location of Monitoring Point/Area Point 1

Monthly Summary for: Oct-12  
 Sample Received Monthly sample received 11/10/12. Other daily and continuous measurements performed through October 2012.  
 Data Obtained 05-Nov-12

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured during month	Min value	Max value	100 percentile limit	Exceedance (Y/N)	Comments
Nitrogen (ammonia)	mg/L	Monthly	1	N./A	5.7	30	N	
Total Copper	mg/L	Monthly	1	N./A	<0.1	N/A	N	
Total Iron	mg/L	Monthly	1	N./A	0.2	2	N	
Total Lead	mg/L	Monthly	1	N./A	<0.01	0.05	N	
Total Manganese	mg/L	Monthly	1	N./A	<0.1	0.5	N	
Total Suspended Solids	mg/L	Monthly	1	N./A	2	20	N	
Total Zinc	mg/L	Monthly	1	N./A	<0.1	2	N	
pH	pH	Continuous	Continuous	7.64	8.35	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	N/A	36.2	42	N	
Volume	kL/day	Daily	Daily	18.6	457	700	N	

Licence 11149  
 Link to Licence <http://www.environment.nsw.gov.au/prpoeoapp/>  
 Name OneSteel Wire Pty Ltd  
 Address Industrial Drive, Mayfield, NSW, 2304  
 Location of Monitoring Point/Area Point 39

Monthly Summary for: Oct-12  
 Sample Received Monthly sample received 10-10-12. Oil and Grease sample received 05-10-12. Other daily and continuous measurements performed through October 2012.  
 Data Obtained 02-Nov-12

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured during month	Min value	Max value	100 percentile limit	Exceedance (Y/N)	Comments
Chromium (hexavalent)	mg/L	Monthly	1	N/A	<0.005	0.01	N	
Nitrogen (ammonia)	mg/L	Monthly	1	N/A	<1	N/A	N	
Phosphate	mg/L	Monthly	1	N/A	0.34	10	N	
Total Copper	mg/L	Monthly	1	N/A	<0.1	N/A	N	
Total Iron	mg/L	Monthly	1	N/A	0.2	5	N	
Total Lead	mg/L	Monthly	1	N/A	<0.1	N/A	N	
Total Manganese	mg/L	Monthly	1	N/A	<0.1	0.5	N	
Total Suspended Solids	mg/L	Monthly	1	N/A	<1	50	N	
Total Zinc	mg/L	Monthly	1	N/A	0.6	3	N	
Oil and Grease	mg/L	Monthly	1	N/A	2	20	N	
pH	pH	Continuous	Continuous	7.5	8.2	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	N/A	37.6	38	N	
Volume	kL/day	Daily	Daily	0	195.5	200	N	