

Licence 11149  
 Link to Licence <http://app.epa.nsw.gov.au/prpoeoapp/>  
 Name Liberty OneSteel Wire  
 Address Industrial Drive, Mayfield, NSW, 2304  
 Location of Monitoring Point/Area Point 1

Monthly Summary for: Apr-18  
 Sample Received Monthly sample received 06/04/18 Other daily and continuous measurements performed through April 2018 .  
 Data Obtained 04-May-18

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured				Exceedance (Y/N)	Comments
			during month	Min value	Max value	100 percentile limit		
Nitrogen (ammonia)	mg/L	Monthly	1	N/A	<1	30	N	
Total Copper	micrograms/L	Monthly	1	N/A	3	N/A	N	
Total Iron	mg/L	Monthly	1	N/A	0.2	2	N	
Total Lead	micrograms/L	Monthly	1	N/A	<1	50	N	
Total Manganese	mg/L	Monthly	1	N/A	<0.1	0.5	N	
Total Suspended Solids	mg/L	Monthly	1	N/A	1	20	N	
Total Zinc	mg/L	Monthly	1	N/A	<0.1	2	N	
pH	pH	Continuous	Continuous	7.7	8.3	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	N/A	39.7	42	N	
Volume	kL/day	Daily	Daily	98	606	700	N	

Licence 11149  
 Link to Licence <http://app.epa.nsw.gov.au/prpoeoapp/>  
 Name Liberty OneSteel Wire  
 Address Industrial Drive, Mayfield, NSW, 2304  
 Location of Monitoring Point/Area Point 39  
 Monthly Summary for: Apr-18  
 Sample Received Monthly sample received 4/4/2018 . Oil and grease 06/4/2018.  
 Other daily and continuous measurements performed through April 2018.  
 Data Obtained 04-May-18

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured				Exceedance (Y/N)	Comments
			during month	Min value	Max value	100 percentile limit		
Chromium (hexavalent)	mg/L	Monthly	1	N/A	0.005	0.01	N	
Nitrogen (ammonia)	mg/L	Monthly	1	N/A	<1	N/A	N	
Phosphate	mg/L	Monthly	1	N/A	6.7	10	N	
Total Copper	micrograms/L	Monthly	1	N/A	4	N/A	N	
Total Iron	mg/L	Monthly	1	N/A	0.1	5	N	
Total Lead	micrograms/L	Monthly	1	N/A	1	N/A	N	
Total Manganese	mg/L	Monthly	1	N/A	<0.1	0.5	N	
Total Suspended Solids	mg/L	Monthly	1	N/A	<1	50	N	
Total Zinc	mg/L	Monthly	1	N/A	0.2	3	N	
Oil and Grease	mg/L	Monthly	1	N/A	<5	20	N	
pH	pH	Continuous	Continuous	7.2	7.9	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	N/A	33.5	38	N	
Volume	kL/day	Daily	Daily	0	295	200	N	

\*One Rain Discharge >200m<sup>3</sup> due to high rainfall on 4th of April of 90mm under Licence condition L3.2