

Licence 11149  
 Link to Licence <http://www.environment.nsw.gov.au/prpoeoapp/>  
 Name OneSteel Wire Pty Ltd (Administrator Appointed)  
 Address Industrial Drive, Mayfield, NSW, 2304  
 Location of Monitoring Point/Area Point 1

Monthly Summary for: Dec-16  
 Sample Received Monthly sample received 6/12/16 Other daily and continuous measurements performed through December 2016 .  
 Data Obtained 15-Dec-16

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured				Exceedance (Y/N)	Comments
			during month	Min value	Max value	100 percentile limit		
Nitrogen (ammonia)	mg/L	Monthly	1	N/A	2	30	N	
Total Copper	micrograms/L	Monthly	1	N/A	3	N/A	N	
Total Iron	mg/L	Monthly	1	N/A	0.4	2	N	
Total Lead	micrograms/L	Monthly	1	N/A	4	50	N	
Total Manganese	mg/L	Monthly	1	N/A	0.1	0.5	N	
Total Suspended Solids	mg/L	Monthly	1	N/A	3	20	N	
Total Zinc	mg/L	Monthly	1	N/A	<0.1	2	N	
pH	pH	Continuous	Continuous	7.7	8.3	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	N/A	41	42	N	
Volume	kL/day	Daily	Daily	0	412	700	N	

Licence 11149  
 Link to Licence <http://www.environment.nsw.gov.au/prpoeoapp/>  
 Name OneSteel Wire Pty Ltd (Administrator Appointed)  
 Address Industrial Drive, Mayfield, NSW, 2304

Location of Monitoring Point/Area Point 39

Monthly Summary for: Dec-16  
 Sample Received Monthly sample received 02/12/16 . Oil and grease 01/12/16.  
 Other daily and continuous measurements performed through December 2016.

Data Obtained 18-Jan-17

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured				Exceedance (Y/N)	Comments
			during month	Min value	Max value	100 percentile limit		
Chromium (hexavalent)	mg/L	Monthly	1	N/A	<0.005	0.01	N	
Nitrogen (ammonia)	mg/L	Monthly	1	N/A	<1	N/A	N	
Phosphate	mg/L	Monthly	1	N/A	0.84	10	N	
Total Copper	micrograms/L	Monthly	1	N/A	3	N/A	N	
Total Iron	mg/L	Monthly	1	N/A	<0.1	5	N	
Total Lead	micrograms/L	Monthly	1	N/A	<1	N/A	N	
Total Manganese	mg/L	Monthly	1	N/A	<0.1	0.5	N	
Total Suspended Solids	mg/L	Monthly	1	N/A	1	50	N	
Total Zinc	mg/L	Monthly	1	N/A	0.5	3	N	
Oil and Grease	mg/L	Monthly	1	N/A	<5	20	N	
pH	pH	Continuous	Continuous	7.4	8.1	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	N/A	36.3	38	N	
Volume	kL/day	Daily	Daily	0	1430	200	N	

Maintenance Discharge on the 2nd and 3rd of December under Licence condition L3.1.